CDN CONTROLS LTD
COMBUSTION & EMISSIONS SERVICES

SHUT DOWN TEST REPORT

Job # :	1803-0270			Date:	March 7, 2018
Company:	NuVista Energy	Contact:	Justin Stover	Phone:	780-814-3877
Email:	justin.stover@nvaenergy.com	Area:	North Wapiti	LSD	15-17-68-8w6

EQUIPMENT INFORMATION

Make:	Enlyn Corp.	Type:	Line Heater	ID:	15-17 LH

DEVICES

Low Level SD. — Tag #: LSLL 101

Make:	SOR	Model:	1510B-G2A-C-L9-ES-CSCV		
Type:		Pneumatic:	☐	Electric:	☑
Test Results:		Pass:	☑	Fail:	☐

Comments:
Tested by rotating 180 degrees simulating a float drop and Profire shut down.



High Temp SD: — Tag #:

Make:	Profire	Model:	2100		
Set Points:	Found	80 °C		Left	80 °C
Test Results:		Pass:	☑	Fail:	☐

Comments:
Tested Good



Temp Control: — Tag #:

Make:	Profire	Model:	2100		
Set Points:	Found	55 °C		Left	55 °C
Test Results:		Pass:	☑	Fail:	☐

Comments:
Tested Good



High Press Sw:	Tag #:			
Make:	CCS	Model:	6900GZE12	
Set Points:	Found 15 ↑ Psi	Left 15 ↑ Psi		
Test Results:	Pass: ☑	Fail: ☐		

Comments:
Tested Good



Low Press Sw:	Tag #:			
Make:	CCS	Model:	6900GZE12	
Set Points:	Found 06 ↓ Psi	Left 06 ↓ Psi		
Test Results:	Pass: ☑	Fail: ☐		

Comments:
Tested Good



Flame Fail	Tag #:			
Make:	Profire	Model:	2100	
Pliot Reading	Found 100 %	Left 100 %		
Test Results:	Pass: ☑	Fail: ☐		

Comments:
Tested Good



Additional Notes:
All Shuts passed and tagged

Combustion Technician	Brandon Peterson	Email	brandon.peterson@cdncontrols.ca